



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18142-73-5819
State Number
27754

EQUIPMENT INSPECTED

State Number: 27754	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: TKE	Speed: 70
Landings: 2	Installed: 05/05/2011	Rope Size:
Volts: 208	Complied:	Entrances: 2
OWNER	OCCUPANT	
RIVERMILL ACADEMY	RIVERMILL ACADEMY	
1242 S MAIN STREET	1242 S MAIN STREET	
GRAHAM, NC, 27253	GRAHAM, NC, 27253	

INSPECTION INFORMATION

Inspection Date 05/22/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.4.7	Remove the water from the pit floor and take steps to prevent its re-entry.
8.6.5.14.1	Provide the annual relief valve and hydraulic system pressure test.
8.6	Remove rust from pit components and take steps to prevent its return

Items must be corrected by: 07/21/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jeff Dishmon 3362290909

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

RIVERMILL ACADEMY
1242 S MAIN STREET
GRAHAM, NC, 27253