



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18149-73-2391
State Number
9610

EQUIPMENT INSPECTED

State Number: 9610	Type of Unit: Freight	Floor to Floor: 1 to 3
Capacity: 5000	Manuf: THYSSEN KRUPP	Speed: 75
Landings: 3	Installed: 05/30/1980	Rope Size:
Volts: 550	Complied: 06/12/1990	Entrances: 1
OWNER	OCCUPANT	
COPLAND FABRICS	COPLAND FABRICS	
PO BOX 1208	1714 CAROLINA MILL RD	
BURLINGTON, NC, 27217	BURLINGTON, NC, 27217	

INSPECTION INFORMATION

Inspection Date 05/29/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

2.7.3.4.1	Provide a self closing self-locking machine room / space door.
8.6.1.6.5	Provide a class ABC fire extinguisher in the machinery space.
8.6.5.14.1	Provide the annual relief valve and hydraulic system pressure test.

Items must be corrected by: 07/28/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Joe Mabe 3362630776

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

COPLAND FABRICS
PO BOX 1208
BURLINGTON, NC, 27217