



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18150-48-4811
State Number
22009

EQUIPMENT INSPECTED

State Number: 22009	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 65
Landings: 2	Installed: 01/09/2004	Rope Size: .
Volts: 230	Complied: 01/09/2004	Entrances: 1
OWNER	OCCUPANT	
NANCY & ROLAND GILLIAM	MCNEIL CO.	
6102 E. OAK ISLAND DR.	6102 E OAK ISLAND DR	
OAK ISLAND, NC, 28465	OAK ISLAND, NC, 28465	

INSPECTION INFORMATION

Inspection Date 05/30/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.1.1.1	Place the in-car Emergency Phone in working order.
8.6.4.19.2 (b)	Provide the annual no load test.

Items must be corrected by: 06/29/2018

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MGMT.

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

NANCY & ROLAND GILLIAM
6102 E. OAK ISLAND DR.
OAK ISLAND, NC, 28465