



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18150-73-3667
State Number
4688

EQUIPMENT INSPECTED

State Number: 4688	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 6000	Manuf: OTIS	Speed: 75
Landings: 2	Installed: 07/09/1973	Rope Size:
Volts: 220	Complied: 07/09/1973	Entrances: 2
OWNER	OCCUPANT	
MOODY BROTHERS PROPERTIES	MOODY BROTHERS PROPERTIES	
PO BOX 2156	673 GILMER STREET	
BURLINGTON, NC, 27216	BURLINGTON, NC, 27217	

INSPECTION INFORMATION

Inspection Date 05/30/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

2.7.3.4.1 Provide a self closing self-locking machine room / space door.

Items must be corrected by: 07/29/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Justin Moody 3362705397

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

MOODY BROTHERS PROPERTIES
PO BOX 2156
BURLINGTON, NC, 27216