



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18151-73-599**  
State Number  
**2553**

EQUIPMENT INSPECTED

|                           |                       |                        |
|---------------------------|-----------------------|------------------------|
| State Number: <b>2553</b> | Type of Unit: Freight | Floor to Floor: 1 to 3 |
| Capacity: 4000            | Manuf: SOUTHERN       | Speed: 75              |
| Landings: 3               | Installed: 05/17/1955 | Rope Size: 1/2         |
| Volts: 220                | Complied: 05/17/1955  | Entrances: 1           |
| OWNER                     | OCCUPANT              |                        |
| DUKE ENERGY               | DUKE POWER CO         |                        |
| PO BOX 1007 ST 30D        | 1205 N CHURCH ST      |                        |
| CHARLOTTE, NC, 28201      | BURLINGTON, NC, 27215 |                        |

INSPECTION INFORMATION

|                               |                            |                                 |                         |                    |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|
| Inspection Date<br>05/31/2018 | Type Inspection<br>Routine | Certificate Status<br>Re-issued | Inspector<br>73 - James | County<br>ALAMANCE |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|

1

VIOLATIONS

8.6.4.7 Remove the water from the pit floor and take steps to prevent its re-entry.

Items must be corrected by: 07/30/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jonathan Pannell 3362225620

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

DUKE ENERGY  
PO BOX 1007 ST 30D  
CHARLOTTE, NC, 28201