



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18156-73-1017
State Number
24960

EQUIPMENT INSPECTED

| | | |
|----------------------------|---------------------------------------|------------------------|
| State Number: 24960 | Type of Unit: Passenger | Floor to Floor: 1 to 3 |
| Capacity: 3000 | Manuf: THYSSEN KRUPP | Speed: 125 |
| Landings: 3 | Installed: 08/21/2007 | Rope Size: |
| Volts: 480 | Complied: | Entrances: 1 |
| OWNER | OCCUPANT | |
| ALAMANCE COMMUNITY COLLEGE | ALAMANCE CC ALLIED HEALTH/PHY SCIENCE | |
| 1247 JIMMIE KERR ROAD | 1247 JIMMY KERR RD | |
| GRAHAM, NC, 27253 | GRAHAM, NC, 27253 | |

INSPECTION INFORMATION

| | | | | |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|
| Inspection Date 06/05/2018 | Type Inspection Routine | Certificate Status Re-issued | Inspector 73 - James | County ALAMANCE |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|

1

VIOLATIONS

5.1.21.1 Place the car alarm bell in working order. Minimum level of 80 dBA.

Items must be corrected by: 08/04/2018

Elevator Name: H BLDG CAR 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: William Hulsey 3365064117

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE COMMUNITY COLLEGE
1247 JIMMIE KERR ROAD
GRAHAM, NC, 27253