N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18156-73-1525
State Number
H615

EQUIPMENT INSPECTED

State Number: **H615**	Type of Unit: Hand Lift	Floor to Floor: G to 1
Capacity: 750	Manuf: NATL W-O-V	Speed: 9
Landings: 2	Installed: 12/30/1994	Rope Size:
Volts: 110	Complied: 01/03/1995	Entrances: 2

OWNER
ALAMANCE - BURLINGTON SCHOOL SYSTEM
1712 VAUGHAN RD
BURLINGTON, NC, 27215

OCCUPANT
WILLIAMS HIGH SCHOOL
1307 S CHURCH ST
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
06/05/2018	Routine	Re-issued	73 - James	ALAMANCE

1

VIOLATIONS

8.6 Replace missing stop switch on platform

Items must be corrected by: 08/04/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Robert Drummond 3365706161 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ALAMANCE - BURLINGTON SCHOOL SYSTEM
1712 VAUGHAN RD
BURLINGTON, NC, 27215