N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18156-73-1537
State Number
24959

EQUIPMENT INSPECTED

State Number: **24959**	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 4500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 3	Installed: 08/21/2007	Rope Size:
Volts: 480	Complied:	Entrances: 1

OWNER	OCCUPANT
ALAMANCE COMMUNITY COLLEGE	ALAMANCE CC ALLIED HEALTH/PHY SCIENCE
1247 JIMMIE KERR ROAD	1247 JIMMY KERR RD
GRAHAM, NC, 27253	GRAHAM, NC, 27253

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
06/05/2018	Routine	Re-issued	73 - James	ALAMANCE

1

VIOLATIONS

Elevator Name: H BLDG CAR 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: William Hulsey 3365064117 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to: ALAMANCE COMMUNITY COLLEGE
1247 JIMMIE KERR ROAD
GRAHAM, NC, 27253