



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18158-48-094
State Number
21788

EQUIPMENT INSPECTED

State Number: 21788	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 06/25/2003	Rope Size: 0
Volts: 208	Complied: 06/25/2003	Entrances: 1
OWNER	OCCUPANT	
SHALLOTTE PRESBYTERIAN CHURCH	SHALLOTTE PRSBYTERIAN CHURCH	
POB 251; 5070 ROURK DR	5070 ROURK DRIVE	
SHALLOTTE, NC, 28459	SHALLOTTE, NC, 28459	

INSPECTION INFORMATION

Inspection Date 06/07/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.19.2 (b) Provide the annual no load test.

Items must be corrected by: 07/07/2018

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Mgmt.

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SHALLOTTE PRESBYTERIAN CHURCH
POB 251; 5070 ROURK DR
SHALLOTTE, NC, 28459