



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18158-48-2226
State Number
24924

EQUIPMENT INSPECTED

State Number: **24924** Type of Unit: Passenger Floor to Floor: 1 to 2
Capacity: Manuf: OTIS Speed: 100
Landings: 2 Installed: 08/23/2007 Rope Size:
Volts: 208 Complied: 08/23/2007 Entrances: 1

OWNER

SHALLOTTE COMMONS,LLC
6752 ROCK SPRINGS RD. SUITE 200
WILMINGTON, NC, 28405

OCCUPANT

SHALLOTTE URGENT CARE
4501 MAIN ST
SHALLOTTE, NC, 28459

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
06/07/2018	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

2.27.1.1.1 Place the in-car Emergency Phone in working order.

Items must be corrected by: 07/07/2018

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Mgmt.

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SHALLOTTE COMMONS,LLC
6752 ROCK SPRINGS RD. SUITE 200
WILMINGTON, NC, 28405