



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18164-73-5213**  
State Number  
**22750**

EQUIPMENT INSPECTED

State Number: <b>22750</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 3	Installed: 04/07/2005	Rope Size:
Volts: 208	Complied: 04/07/2005	Entrances: 1
OWNER	OCCUPANT	
ALAMANCE COUNTRY CLUB	ALAMANCE COUNTRY CLUB	
2402 PINEWAY DRIVE	2402 PINEWAY DRIVE	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 06/13/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

- 8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machinery spaces, machine rooms, control spaces and control rooms.
- 8.6.4.7 Remove the water from the pit floor and take steps to prevent its re-entry.
- 2.7.9.1 Place the machine room or space lights in working order. 200 lx or 19 fc @ the machine room floor.
- 2.7.3.4.1 Provide a self closing self-locking machine room / space door.
- 2.14.7.1.2 Place the passenger cab interior lights in working order. 50 lx or 5 fc @ the cab floor.

Items must be corrected by: 07/13/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jonathan Spence 3365844115

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE COUNTRY CLUB  
2402 PINEWAY DRIVE  
BURLINGTON, NC, 27215