N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18165-48-4588
State Number
15400

EQUIPMENT INSPECTED

State Number: **15400**
Capacity: 4500
Landings: 3
Volts: 480

Type of Unit: Passenger
Manuf: OTIS
Installed: 06/22/1994
Complied: 08/19/1994

Floor to Floor: 1 to 3
Speed: 125
Rope Size:
Entrances: 1

OWNER
DUKE ENERGY
8470 RIVER ROAD SE
SOUTHPORT, NC, 28461

OCCUPANT
DUKE ENERGY - MTCE. BLDG.
8470 RIVER ROAD SE
SOUTHPORT, NC, 28461

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
06/14/2018	Routine	Re-issued	48 - Martin	BRUNSWICK	10

VIOLATIONS

3.24.1 Hydraulic Machines And Tanks [PROVIDE SEAL ON VALVE]

Items must be corrected by: 07/14/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: BRYAN NEALY

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
DUKE ENERGY
8470 RIVER ROAD SE
SOUTHPORT, NC, 28461