



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18165-73-0849
State Number
23486

EQUIPMENT INSPECTED

State Number: 23486	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 09/22/2005	Rope Size:
Volts: 208	Complied: 09/26/2005	Entrances: 1
OWNER	OCCUPANT	
JR OUTLET MALL	JR OUTLET MALL	
2589-A ERIC LANE	2589-A ERIC LANE	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 06/14/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

- 2.7.9.1 Place the machine room or space lights in working order. 200 lx or 19 fc @ the machine room floor.
5.1.21.1 Place the car alarm bell in working order. Minimum level of 80 dBA.

Items must be corrected by: 08/13/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: J Capes

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

JR OUTLET MALL
2589-A ERIC LANE
BURLINGTON, NC, 27215