



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18165-73-2177**  
State Number  
**14972**

EQUIPMENT INSPECTED

State Number: <b>14972</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 11/19/1993	Rope Size:
Volts: 460	Complied: 12/08/1993	Entrances: 1
OWNER	OCCUPANT	
ALAMANCE COUNTY	CRIMINAL COURTS BLDG	
124 W ELM ST	W ELM ST	
GRAHAM, NC, 27253	GRAHAM, NC, 27253	

INSPECTION INFORMATION

Inspection Date 06/14/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

2.14.7.1.2	Place the passenger cab interior lights in working order. 50 lx or 5 fc @ the cab floor.
2.27.1.1.1	Place the in-car Emergency Phone in working order.

Items must be corrected by: 08/13/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Calvin Phillips 3362641285

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE COUNTY  
124 W ELM ST  
GRAHAM, NC, 27253