



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18170-73-3313**  
State Number  
**15908**

EQUIPMENT INSPECTED

State Number: <b>15908</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 06/26/1995	Rope Size:
Volts: 460	Complied: 06/28/1995	Entrances: 1
OWNER	OCCUPANT	
ANDY ALBRIGHT	NATIONAL AGENTS ALLIANCE	
215 ALTAMAHAWA UNION RIDGE ROAD	1214 TURRENTINE ST	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 06/19/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

2.14.7.1.2	Place the passenger cab interior lights in working order. 50 lx or 5 fc @ the cab floor.
8.6	Place GFI recepticle on cartop in working order
8.6	Place in case of fire sign at each landing

Items must be corrected by: 07/19/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Carissa King 3362273319

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ANDY ALBRIGHT  
215 ALTAMAHAWA UNION RIDGE ROAD  
BURLINGTON, NC, 27215