



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18171-73-2334
State Number
30527

EQUIPMENT INSPECTED

| | | |
|----------------------------|--------------------------|------------------------|
| State Number: 30527 | Type of Unit: Passenger | Floor to Floor: 1 to 2 |
| Capacity: 3500 | Manuf: TKE | Speed: 110 |
| Landings: 2 | Installed: 11/01/2016 | Rope Size: |
| Volts: 208 | Complied: 11/01/2016 | Entrances: 1 |
| OWNER | OCCUPANT | |
| LIDL US OPERATION LLC | GES 002 | |
| 3500 S CLARK STREET | 3815 SENATOR RALPH SCOTT | |
| ARLINGTON, VA, 22202 | GRAHAM, NC, 27217 | |

INSPECTION INFORMATION

| | | | | |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|
| Inspection Date 06/20/2018 | Type Inspection Routine | Certificate Status Re-issued | Inspector 73 - James | County ALAMANCE |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|

1

VIOLATIONS

2.27.1.1.1 Place the in-car Emergency Phone in working order.

Items must be corrected by: 08/19/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Bob Tadjalli 7033469196

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LIDL US OPERATION LLC
3500 S CLARK STREET
ARLINGTON, VA, 22202