



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18171-73-2926**  
State Number  
**26694**

EQUIPMENT INSPECTED

State Number: <b>26694</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: TKE	Speed: 110
Landings: 2	Installed: 07/13/2009	Rope Size:
Volts: 200	Complied:	Entrances: 2
OWNER	OCCUPANT	
CITY OF MEBANE	MEBANE OLD RECREATION CENTER	
160 E WASHINGTON ST	210 LEE ST	
MEBANE, NC, 27302	MEBANE, NC, 27302	

INSPECTION INFORMATION

Inspection Date 06/20/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.1.6.5 Provide a class ABC fire extinguisher in the machinery space. Current one has expired inspection

Items must be corrected by: 08/19/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Stephanie Shaw

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CITY OF MEBANE  
160 E WASHINGTON ST  
MEBANE, NC, 27302