N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18176-73-0559
State Number
14792

EQUIPMENT INSPECTED

State Number: **14792**
Capacity: 12600
Landings: 2
Volts: 480

Type of Unit: Freight
Manuf: ASK
Installed: 08/28/1992
Complied: 08/28/1992

Floor to Floor: 1 to 2
Speed: 45
Rope Size:
Entrances: 1

OWNER
CAROLINA HOISERY MILLS, INC.
PO BOX 850
BURLINGTON, NC, 27216

OCCUPANT
AMERICAN MULTI MEDIA
2609 TUCKER ST
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
06/25/2018	Routine	Re-issued	73 - James	ALAMANCE

1

VIOLATIONS

5.1.21.1 Place the car alarm bell in working order. Minimum level of 80 dBA.

Items must be corrected by: 08/24/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Keith Greeson 3362602676 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
CAROLINA HOISERY MILLS, INC.
PO BOX 850
BURLINGTON, NC, 27216