



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18176-73-1581
State Number
14791

EQUIPMENT INSPECTED

State Number: 14791	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 12600	Manuf: ASK	Speed: 45
Landings: 2	Installed: 09/04/1992	Rope Size:
Volts: 480	Complied: 09/04/1992	Entrances: 1
OWNER	OCCUPANT	
CAROLINA HOISERY MILLS, INC.	AMERICAN MULTI MEDIA	
PO BOX 850	2609 TUCKER ST	
BURLINGTON, NC, 27216	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 06/25/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

5.1.21.1 Place the car alarm bell in working order. Minimum level of 80 dBA.

Items must be corrected by: 08/24/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Keith Greeson 3366868118

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CAROLINA HOISERY MILLS, INC.
PO BOX 850
BURLINGTON, NC, 27216