



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18177-73-153
State Number
7551

EQUIPMENT INSPECTED

State Number: 7551	Type of Unit: Freight	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: WESTBROOK	Speed: 75
Landings: 3	Installed: 07/20/1973	Rope Size: 1/2
Volts: 460	Complied: 07/20/1973	Entrances: 1
OWNER	OCCUPANT	
TRAILHEAD CHURCH	TRAILHEAD CHURCH	
615 W HARDEN ST	615 W HARDEN ST	
GRAHAM, NC, 27253	GRAHAM, NC, 27253	

INSPECTION INFORMATION

Inspection Date 06/26/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.4.7	Clean the pit and the pit equipment.
8.6.1.6.5	Provide a class ABC fire extinguisher in the machinery space.
2.7.3.4.1	Provide a self closing self-locking machine room / space door.

Items must be corrected by: 08/25/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: David Deblecourt 3366930722

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

TRAILHEAD CHURCH
615 W HARDEN ST
GRAHAM, NC, 27253