



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18179-48-1469
State Number
26649

EQUIPMENT INSPECTED

State Number: **26649**

Capacity: 3000

Landings: 3

Volts: 208

Type of Unit: Passenger

Manuf: OTIS

Installed: 04/22/2009

Complied:

Floor to Floor: 1 to 3

Speed: 125

Rope Size:

Entrances: 1

OWNER

LELAND HOLDINGS,LLC ADB HOLIDAYINN EXPRE
1020 GRANDIFLORA DRIVE
LELAND, NC, 28451

OCCUPANT

HOLIDAYINN EXPRESS
1020 GRANDIFLORA DRIVE
LELAND, NC, 28451

INSPECTION INFORMATION

Inspection Date
06/28/2018

Type Inspection
Routine

Certificate Status
Re-issued

Inspector
48 - Martin

County
BRUNSWICK

10

VIOLATIONS

8.6.4.7 Clean the pit and the pit equipment.

Items must be corrected by: 07/28/2018

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: T. GREEN

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LELAND HOLDINGS,LLC ADB HOLIDAYINN EXPRE
1020 GRANDIFLORA DRIVE
LELAND, NC, 28451