



INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18180-79-3834**  
State Number  
**29721**

EQUIPMENT INSPECTED

State Number: <b>29721</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: TKE	Speed: 125
Landings: 2	Installed: 05/18/2015	Rope Size:
Volts: 208	Complied: 05/18/2015	Entrances: 1
OWNER	OCCUPANT	
CITY OF WASHINGTON	WARREN FIELD AIRPORT	
102 E 2ND STREET	200 AIRPORT ROAD	
WASHINGTON, NC, 27889	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 06/29/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 79 - Cumberland	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	------------------------------	--------------------

7

VIOLATIONS

2.27.1.1.1 Place the in-car Emergency Phone in working order. ( only few seconds to speak )

Items must be corrected by: 08/28/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: main office

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CITY OF WASHINGTON  
102 E 2ND STREET  
WASHINGTON, NC, 27889