



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18186-76-0822
State Number
29061

EQUIPMENT INSPECTED

State Number: 29061	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: TKE	Speed: 45
Landings: 3	Installed: 12/09/2013	Rope Size:
Volts: 230	Complied: 12/09/2013	Entrances: 2

OWNER

FIRST BAPTIST CHURCH OF SPARTA
202 S MAIN STREET
SPARTA, NC, 28675

OCCUPANT

FIRST BAPTIST CHURCH OF SPARTA
202 S MAIN STREET
SPARTA, NC, 28675

INSPECTION INFORMATION

Inspection Date 07/05/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ALLEGHANY
-------------------------------	----------------------------	---------------------------------	-------------------------	---------------------

3

VIOLATIONS

2.27.1.1.1 Place the in-car Emergency Phone in working order.with power off

Items must be corrected by: 08/04/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: First Baptist Church Sparta 336-372-8446

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

FIRST BAPTIST CHURCH OF SPARTA
202 S MAIN STREET
SPARTA, NC, 28675