



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18186-76-3171**  
State Number  
**24155**

### EQUIPMENT INSPECTED

State Number: <b>24155</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 110
Landings: 2	Installed: 10/30/2006	Rope Size: 0
Volts: 208	Complied: 10/30/2006	Entrances: 1
OWNER	OCCUPANT	
ALLEGHENY COUNTY	ALLEGHENYCOUNTY COURT HOUSE	
348 S MAIN STREET	12 N MAIN STREET	
SPARTA, NC, 29063	SPARTA, NC, 29063	

### INSPECTION INFORMATION

Inspection Date 07/05/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ALLEGHANY
-------------------------------	----------------------------	---------------------------------	-------------------------	---------------------

3

### VIOLATIONS

- 8.6.1.6.5 Provide a NBCC Class ABC fire extinguisher convenient to the access door in the machine room / space. SECOND NOTICE
- 8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machinery spaces, machine rooms, control spaces and control rooms. SECOND NOTICE

Items must be corrected by: 08/04/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Josh Greene 336-372-2010

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALLEGHENY COUNTY  
348 S MAIN STREET  
SPARTA, NC, 29063