N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18186-76-4657
State Number
11828

EQUIPMENT INSPECTED

State Number: **11828**
Capacity: 2100
Landings: 2
Volts: 240

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 10/01/1986
Complied: 10/01/1986

Floor to Floor: 1 to 2
Speed: 100
Rope Size:
Entrances: 1

OWNER
ALLEGHANY COUNTY
348 S MAIN STREET
SPARTA, NC, 28675

OCCUPANT
ALLEG CO / SR CITIZEN CTR
MAIN ST
SPARTA, NC, 28675

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
07/05/2018	Routine	Re-issued	76 - Crank	ALLEGHANY

3

VIOLATIONS

2.7.3.4.1 Provide a self closing self-locking machine room / space door.
8.6.1.6.5 Provide a NBCC Class ABC fire extinguisher convienent to the access door in the machine room / space.
2.27.1.1.1 Place the in-car Emergency Phone in working order.

Items must be corrected by: 09/03/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Alleghany Co Senior Citizen 333-372-2010 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to: ALLEGHANY COUNTY
348 S MAIN STREET
SPARTA, NC, 28675