



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18187-76-0624
State Number
11205

EQUIPMENT INSPECTED

State Number: 11205	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 3	Installed: 07/25/1985	Rope Size:
Volts: 220	Complied: 07/25/1985	Entrances: 2
OWNER	OCCUPANT	
THE GREYSTONE INN	THE GREYSTONE INN	
2663 ROARING GAP DR.	2663 ROARING GAP DR.	
ROARING GAP, NC, 28668	ROARING GAP, NC, 28668	

INSPECTION INFORMATION

Inspection Date 07/06/2018	Type Inspection Compliance	Certificate Status Prev Issued	Inspector 76 - Crank	County ALLEGHANY
-------------------------------	-------------------------------	-----------------------------------	-------------------------	---------------------

3

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Greystone Inn 336-363-2211

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

THE GREYSTONE INN
2663 ROARING GAP DR.
ROARING GAP, NC, 28668