



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18187-76-5519
State Number
H1898

EQUIPMENT INSPECTED

State Number: H1898	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: TKE	Speed: 12
Landings: 2	Installed: 08/27/2007	Rope Size:
Volts: 120	Complied:	Entrances: 2
OWNER		OCCUPANT
MORAVIAN CHURCH IN AMERICA SOUTHERN PROV		HIGGINS LODGE EXPANSION
124 PENDRY DRIVE		124 PENDRY DRIVE
LAUREL SPRINGS, NC, 28644		LAUREL SPRINGS, NC, 28644

INSPECTION INFORMATION

Inspection Date 07/06/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ALLEGHANY
-------------------------------	----------------------------	---------------------------------	-------------------------	---------------------

3

VIOLATIONS

- 2.14.7.1.3 SECOND NOTICE Place the in-car emergency lights in working order. The auxillary lighting illumination shall not be less than 2 lx (0.2 fc) measured at any point between 48 in. and 35 in. above the car floor
- 2.27.1.1.1 Place the in-car Emergency Phone in working order.

Items must be corrected by: 08/05/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Thomas 336-359-2951

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

MORAVIAN CHURCH IN AMERICA SOUTHERN PROV
124 PENDRY DRIVE
LAUREL SPRINGS, NC, 28644