



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18193-48-0136
State Number
22891

EQUIPMENT INSPECTED

State Number: 22891	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: OTIS	Speed: 100
Landings: 3	Installed: 03/02/2005	Rope Size: 0
Volts: 240	Complied: 03/02/2005	Entrances: 1
OWNER COMMUNITY ASSOCIATION MGMT. P.O. BOX 8126 OCEAN ISLE, NC, 28469	OCCUPANT VILLAS ON OSPREY RIDGE 184 CLUBHOUSE RD. SUNSET BEACH, NC, 28468	

INSPECTION INFORMATION

Inspection Date 07/12/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.7	Clean the pit and the pit equipment.
2.27.1.1.1	Place the in-car Emergency Phone in working order.
N/A	LOOSE HAND RAIL IN CAR

Items must be corrected by: 08/11/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

COMMUNITY ASSOCIATION MGMT.
P.O. BOX 8126
OCEAN ISLE, NC, 28469