

Violations pointed out to: UNAVAILABLE

THIS IS NOT AN

INVOICE

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm 919-707-7927 Report Number 18198-48-1736 State Number 26116

| EQUIPMENT INSPECTED | | | | | |
|--------------------------------------------------------------------------|------------------------------------|----------------------------------|----------------------------|---------------------------|----|
| State Number: 26116 | Type of Unit: Passenger | | Floor to Floor: 1 to 2 | | |
| Capacity: 2000 | Manuf: TKE | | Speed: 100 | | |
| Landings: 2 | Installed: 02/13/2012 Complied: | | Rope Size: Entrances: 1 | | |
| Volts: 200 | | | | | |
| OWNER | | OCCUPAN | NT | | |
| CAROLINA DREAMS GOLF LLC | SUNSET (| | OFFICE BUILDING | | |
| 337 PENCO DR. | 690 SUNSET | | ET BLVD | T BLVD | |
| WEIRDON, WV, 26062 | SUNSET BEACH, NC, 28464 | | | | |
| | | INSPECTION INFORMATION | | | |
| Inspection Date 07/17/2018 | Type Inspection Routine | Certificate Status Re-issued | Inspector 48 - Martin | County BRUNSWICK | 10 |
| | | VIOLATIONS | | | |
| 8.6.4.7 Clean the pit and the pit equipment. | | | | | |
| 8.6.4.19.2 (b) | Provide the annual n | o load test. | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| Items must be corrected by: 08/16/ | | Elevator Name: # 1 | | | |
| Notify the Elevator Bureau in writing of complainace with current codes. | on Corrected Violations Form | m when the following corrections | have been made in order to | bring your equipment into | |

337 PENCO DR. WEIRDON, WV, 26062

CAROLINA DREAMS GOLF LLC

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

Inspector ___