



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18198-48-286
State Number
27592

EQUIPMENT INSPECTED

State Number: 27592	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: TKE	Speed: 100
Landings: 3	Installed: 10/20/2010	Rope Size:
Volts: 208	Complied: 10/20/2010	Entrances: 1
OWNER	OCCUPANT	
VILLAGE PARK PROPERTY OWNER ASSOCIATION	VILLAGE PARK CONDOMINIUMS	
1842 BANKING ST.	7825 HIGH MARKET STREET	
GREENSBORO, NC, 27408	SUNSET BEACH, NC, 28468	

INSPECTION INFORMATION

Inspection Date 07/17/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.1.1.1 Place the in-car Emergency Phone in working order.

Items must be corrected by: 08/16/2018

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

VILLAGE PARK PROPERTY OWNER ASSOCIATION
1842 BANKING ST.
GREENSBORO, NC, 27408