



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18198-48-504
State Number
25287

EQUIPMENT INSPECTED

State Number: 25287	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: TKE	Speed: 125
Landings: 3	Installed: 02/06/2008	Rope Size:
Volts: 208	Complied: 02/06/2008	Entrances: 1
OWNER	OCCUPANT	
VILLAGE PARK PROPERTY OWNERS ASSOCIATION	VILLAGE PARK CONDOS	
1482 BANKING ST.	7827 HIGH MARKET STREET	
GREENSBORO, NC, 27408	SUNSET BEACH, NC, 28468	

INSPECTION INFORMATION

Inspection Date 07/17/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

5.1.21.1 Place the car alarm bell in working order. Minimum level of 80 dBA.

Items must be corrected by: 08/16/2018

Elevator Name: BLDG 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

VILLAGE PARK PROPERTY OWNERS ASSOCIATION
1482 BANKING ST.
GREENSBORO, NC, 27408