



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18198-70-4499
State Number
9763

EQUIPMENT INSPECTED

State Number: 9763	Type of Unit: Freight	Floor to Floor: 1 to 3
Capacity: 6000	Manuf: SOUTHERN	Speed: 100
Landings: 3	Installed: 10/22/1980	Rope Size:
Volts: 220	Complied: 10/22/2004	Entrances: 1
OWNER	OCCUPANT	
WADE MANUFACTURING CO.	WADE MANUFACTURING CO.	
P.O.BOX 32	HIGHWAY 74 EAST	
WADESBORO, NC, 28170	WADESBORO, NC, 28170	

INSPECTION INFORMATION

Inspection Date 07/17/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 70 - Darnley	County ANSON
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

4

VIOLATIONS

8.6.4.7 Remove the water from the pit floor and take steps to prevent its re-entry.

Items must be corrected by: 09/15/2018

Elevator Name: SHOP ELEVATOR

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Ken Greene (Slew) 704-694-2131

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WADE MANUFACTURING CO.
P.O.BOX 32
WADESBORO, NC, 28170