



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18200-70-5436
State Number
21244

EQUIPMENT INSPECTED

State Number: 21244	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 2	Installed: 09/04/2003	Rope Size: 0
Volts: 480	Complied: 09/04/2003	Entrances: 1
OWNER		OCCUPANT
LANESBORO CORRECTIONAL INSTITUTION		LANESBORO CORRECTIONAL INSTITUTION
P.O.BOX 280		552 PRISON CAMP RD
POLKTON, NC, 28135		POLKTON, NC, 28135

INSPECTION INFORMATION

Inspection Date 07/19/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 70 - Darnley	County ANSON
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

4

VIOLATIONS

2.27.1.1.1 Place the in-car Emergency Phone in working order.

Items must be corrected by: 09/17/2018

Elevator Name: RICHMOND BLDG

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Andy Brewer 704-695-1013

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LANESBORO CORRECTIONAL INSTITUTION
P.O.BOX 280
POLKTON, NC, 28135