



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18201-70-092
State Number
2050

EQUIPMENT INSPECTED

State Number: 2050	Type of Unit: Freight	Floor to Floor: B to 2
Capacity: 1500	Manuf: ROTARY	Speed: 50
Landings: 2	Installed: 04/03/1953	Rope Size:
Volts: 220	Complied: 04/03/1989	Entrances: 2
OWNER	OCCUPANT	
ANSON CO ADMIN BLDG	ANSON CO ADMIN BLDG	
101 S.GRENE ST	101 S.GRENE ST ROOM 30	
WADESBORO, NC, 28170	WADESBORO, NC, 28170	

INSPECTION INFORMATION

Inspection Date 07/20/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 70 - Darnley	County ANSON
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

4

VIOLATIONS

8.6.5.14.1 Provide the annual relief valve and hydraulic system pressure test.

Items must be corrected by: 09/18/2018

Elevator Name: SIDEWALK ELEV

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Alan Clark 704-694-2796

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ANSON CO ADMIN BLDG
101 S.GRENE ST
WADESBORO, NC, 28170