



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18201-70-2548
State Number
7235

EQUIPMENT INSPECTED

State Number: 7235	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 1500	Manuf: THYSSEN KRUPP	Speed: 75
Landings: 2	Installed: 09/19/1972	Rope Size:
Volts: 220	Complied: 06/20/2000	Entrances: 1
OWNER	OCCUPANT	
ANSON CO ADMIN BLDG	HAMPTON B ALLEN LIBRARY	
101 S. GREENE ST	120 S GREENE ST	
WADESBORO, NC, 28170	WADESBORO, NC, 28170	

INSPECTION INFORMATION

Inspection Date 07/20/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 70 - Darnley	County ANSON
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

4

VIOLATIONS

8.6.5.14.1 Provide the annual relief valve and hydraulic system pressure test.

Items must be corrected by: 09/18/2018

Elevator Name: PASSENGER ELEVATOR

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Alan Clark 704-695-2796

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ANSON CO ADMIN BLDG
101 S. GREENE ST
WADESBORO, NC, 28170