N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18205-76-241
State Number
11397

EQUIPMENT INSPECTED

State Number: **11397**
Capacity: 2000
Landings: 2
Volts: 480

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 08/22/1985
Complied: 08/22/1985

Floor to Floor: 1 to 2
Speed: 100
Rope Size:
Entrances: 1

OWNER
ALLEGHANY COUNTY
85 PEACHTREE ST
SPARTA, NC, 28675

OCCUPANT
ALLEGHANY HIGH SCHOOL
404 TROJAN AVE
SPARTA, NC, 28675

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
07/24/2018	Routine	Re-issued	76 - Crank	ALLEGHANY

3

VIOLATIONS

2.7.9.1 Place the machine room or space lights in working order. 200 lx or 19 fc @ the machine room floor.

8.6.1.6.5 Provide a NBCC Class ABC fire extinguisher convienent to the access door in the machine room / space.

Items must be corrected by: 09/22/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Alleghany High School 336-372-4345 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ALLEGHANY COUNTY
85 PEACHTREE ST
SPARTA, NC, 28675