



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18207-48-158
State Number
29938

EQUIPMENT INSPECTED

| | | |
|----------------------------|--------------------------|------------------------|
| State Number: 29938 | Type of Unit: Passenger | Floor to Floor: 1 to 2 |
| Capacity: 2500 | Manuf: OTIS | Speed: 100 |
| Landings: 2 | Installed: 06/02/2015 | Rope Size: |
| Volts: 208 | Complied: | Entrances: 1 |
| OWNER | OCCUPANT | |
| JOHN WARD | COMFORT INN SHALLOTTE #1 | |
| 11 BRIER WOOD ROAD | 360 WHITEVILLE ROAD | |
| SHALLOTTE, NC, 28470 | SHALLOTTE, NC, 28459 | |

INSPECTION INFORMATION

| | | | | |
|-------------------------------|----------------------------|---------------------------------|--------------------------|---------------------|
| Inspection Date 07/26/2018 | Type Inspection Routine | Certificate Status Re-issued | Inspector 48 - Martin | County BRUNSWICK |
|-------------------------------|----------------------------|---------------------------------|--------------------------|---------------------|

10

VIOLATIONS

8.6.4.19.2 (b) Provide the annual no load test.

Items must be corrected by: 08/25/2018

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: PAUL

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

JOHN WARD
11 BRIER WOOD ROAD
SHALLOTTE, NC, 28470