



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18213-48-0660
State Number
24906

EQUIPMENT INSPECTED

State Number: 24906	Type of Unit: Passenger	Floor to Floor: 1 to 6
Capacity: 3500	Manuf: OTIS	Speed: 150
Landings: 6	Installed: 06/25/2007	Rope Size:
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
SEASIDELANDING PARTNERS LLC	SEASIDE LANDING CONDOS	
7265 SEASHELL LANE SW	7265 SEASHELL LANE SW	
OCEAN ISLE BEACH, NC, 28469	OCEAN ISLE BEACH, NC, 28469	

INSPECTION INFORMATION

Inspection Date 08/01/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

- 2.8.1 Only machinery and equipment used directly in connection with the elevator shall be permitted in elevator hoistways, machinery spaces, machine rooms, control spaces, and control rooms.

Items must be corrected by: 08/31/2018

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SEASIDELANDING PARTNERS LLC
7265 SEASHELL LANE SW
OCEAN ISLE BEACH, NC, 28469