



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18214-48-3570
State Number
30972

EQUIPMENT INSPECTED

State Number: 30972	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3500	Manuf: TKE	Speed: 35
Landings: 3	Installed: 07/17/2017	Rope Size:
Volts: 230	Complied: 07/17/2017	Entrances: 1
OWNER HAWTHORNE RESIDENTIAL PROPERTIES 2918A MARTINSVILLE ROAD LELAND, NC, 27408		OCCUPANT HAWTHORNE AY LELAND CAR 3 9490 PLOOF ROAD SE LELAND, NC, 28541

INSPECTION INFORMATION

Inspection Date 08/02/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.19.2 (b) Provide the annual no load test.

Items must be corrected by: 09/01/2018

Elevator Name: # 3

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

HAWTHORNE RESIDENTIAL PROPERTIES
2918A MARTINSVILLE ROAD
LELAND, NC, 27408