



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18225-76-5967
State Number
19010

EQUIPMENT INSPECTED

State Number: 19010	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: KONE	Speed: 125
Landings: 3	Installed: 10/18/2000	Rope Size:
Volts: 480	Complied: 10/26/2000	Entrances: 2
OWNER	OCCUPANT	
ASHE CO BOARD OF COMMERCE	ASHE CO GOVERNMENT COMPLEX	
150 GOV'T CIRCLE STE 2500	150 GOV'T CIRCLE	
JEFFERSON, NC, 28640	JEFFERSON, NC, 28640	

INSPECTION INFORMATION

Inspection Date 08/13/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ASHE
-------------------------------	----------------------------	---------------------------------	-------------------------	----------------

5

VIOLATIONS

- 8.6.4.13.1 (f) Properly maintain the hoistway door rollers. (replace or adjust)
- 2.27.7.1 Replace the Phase I Fire Service instruction sign @ the designated landing.
- 2.14.7.1.3 Place the in-car emergency lights in working order. The auxillary lighting illumination shall not be less than 2 lx (0.2 fc) measured at any point between 48 in. and 35 in. above the car floor and approximately 12 in. centered horizontally in front o
- 5.1.21.1 Place the car alarm bell in working order. Minimum level of 80 dBA.with the power off

Items must be corrected by: 10/12/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Gary 336-977-6265

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHE CO BOARD OF COMMERCE
150 GOV'T CIRCLE STE 2500
JEFFERSON, NC, 28640