



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18228-70-224
State Number
613

EQUIPMENT INSPECTED

State Number: 613	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: MONARCH	Speed: 50
Landings: 2	Installed: 12/21/1945	Rope Size: 1/2
Volts: 220	Complied: 06/25/2004	Entrances: 1
OWNER	OCCUPANT	
WILLIAM IVEY	SOUTHERN ANTIQUES & POTTERY/ CLOCK SHOP	
118 S CHURCH ST	118 S CHURCH ST	
ASHEBORO, NC, 27203	ASHEBORO, NC, 27203	

INSPECTION INFORMATION

Inspection Date 08/16/2018	Type Inspection Routine	Certificate Status Not Issued	Inspector 70 - Darnley	County RANDOLPH
-------------------------------	----------------------------	----------------------------------	---------------------------	--------------------

76

VIOLATIONS

- 2.27.1.1.1 Place the in-car Emergency Phone in working order.
- 8.6.4.20.1 Provide the 5 year full load test.REPEAT VIOLATION
- 8.1.1.(c) Provide machine room keys on premises. Keys shall be kept on the premises in a location readily accessible to elevator personnel but not where they are accessible to the general public.REPEAT VIOLATION

Items must be corrected by: 09/15/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: William Ivey 336-318-5120

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WILLIAM IVEY
118 S CHURCH ST
ASHEBORO, NC, 27203