



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18234-76-1813
State Number
17534

EQUIPMENT INSPECTED

State Number: 17534	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 06/08/1999	Rope Size:
Volts: 480	Complied: 06/08/1999	Entrances: 1

OWNER

ASHE COUNTY BOARD OF EDUCATION
PO BOX 604
JEFFERSON, NC, 28640

OCCUPANT

ASHE COUNTY HIGH SCHOOL
184 CAMPUS DR
WEST JEFFERSON, NC, 28694

INSPECTION INFORMATION

Inspection Date 08/22/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ASHE
-------------------------------	----------------------------	---------------------------------	-------------------------	----------------

5

VIOLATIONS

- 2.29.1 Assign identification numbers or letters to the equipment where required. Replace missing "DO NOT USE IN CASE OF FIRE" signs
- 8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machinery spaces, machine rooms, control spaces and control rooms.

Items must be corrected by: 10/21/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Kenny 336-246-7175

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHE COUNTY BOARD OF EDUCATION
PO BOX 604
JEFFERSON, NC, 28640