



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18235-48-535
State Number
H1766

EQUIPMENT INSPECTED

State Number: H1766	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: ACC	Speed: 18
Landings: 2	Installed: 06/26/2006	Rope Size: 0
Volts: 115	Complied: 06/26/2006	Entrances: 2
OWNER	OCCUPANT	
RIVERS EDGE POA	RIVERS EDGE BEACH CLUB	
P. O. BOX 6895	471 OCEAN BLVD	
OCEAN ISLE, NC, NC, 28469	HOLDEN BEACH, NC, 28462	

INSPECTION INFORMATION

Inspection Date 08/23/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.1.1.1 Place the in-car Emergency Phone in working order.

Items must be corrected by: 09/22/2018

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

RIVERS EDGE POA
P. O. BOX 6895
OCEAN ISLE, NC, NC, 28469