



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18253-70-2619**  
State Number  
**5219**

EQUIPMENT INSPECTED

|                           |                         |                        |
|---------------------------|-------------------------|------------------------|
| State Number: <b>5219</b> | Type of Unit: Passenger | Floor to Floor: 1 to 2 |
| Capacity: 2500            | Manuf: WESTBROOK        | Speed: 75              |
| Landings: 2               | Installed: 07/19/1965   | Rope Size:             |
| Volts: 240                | Complied: 05/20/2003    | Entrances: 1           |
| OWNER                     | OCCUPANT                |                        |
| DAVID & JANET RICH        | COLLECTORS ANTIQUE MALL |                        |
| 211 SUNSET AVE            | 211 SUNSET AVE          |                        |
| ASHEBORO, NC, 27203       | ASHEBORO, NC, 27203     |                        |

INSPECTION INFORMATION

|                               |                            |                                 |                           |                    |
|-------------------------------|----------------------------|---------------------------------|---------------------------|--------------------|
| Inspection Date<br>09/10/2018 | Type Inspection<br>Routine | Certificate Status<br>Re-issued | Inspector<br>70 - Darnley | County<br>RANDOLPH |
|-------------------------------|----------------------------|---------------------------------|---------------------------|--------------------|

76

VIOLATIONS

2.7.3.4.1 Provide a self closing self-locking machine room / space door. Repair door

Items must be corrected by: 11/09/2018

Elevator Name: VISITOR

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: David Rich 336-629-8105

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

DAVID & JANET RICH  
211 SUNSET AVE  
ASHEBORO, NC, 27203