



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18254-76-1492**  
State Number  
**6737**

EQUIPMENT INSPECTED

State Number: <b>6737</b>	Type of Unit: Passenger	Floor to Floor: B to 3
Capacity: 4000	Manuf: SOUTHERN	Speed: 200
Landings: 4	Installed: 08/04/1971	Rope Size: 1/2
Volts: 208	Complied: 08/20/1971	Entrances: 1
OWNER	OCCUPANT	
ASHE MEMORIAL HOSPITAL	ASHE MEMORIAL HOSPITAL	
200 HOSPITAL AVENUE	200 HOSPITAL DR.	
JEFFERSON, NC, 28640	JEFFERSON, NC, 28640	

INSPECTION INFORMATION

Inspection Date 09/11/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ASHE
-------------------------------	----------------------------	---------------------------------	-------------------------	----------------

5

VIOLATIONS

- 2.27.1.1.1 Place the in-car Emergency Phone in working order.
- 8.6.1.6.5 Provide a NBCC Class ABC fire extinguisher convenient to the access door in the machine room / space.

Items must be corrected by: 10/11/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Gayland 336-846-0720

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHE MEMORIAL HOSPITAL  
200 HOSPITAL AVENUE  
JEFFERSON, NC, 28640