



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**18254-76-5841**  
State Number  
**20110**

EQUIPMENT INSPECTED

State Number: <b>20110</b>	Type of Unit: Passenger	Floor to Floor: G to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 3	Installed: 04/17/2001	Rope Size:
Volts: 208	Complied: 04/17/2001	Entrances: 1
OWNER	OCCUPANT	
REEVES LAW FIRM	REEVES LAW FIRM	
PO DRAWER 67	202 E MAIN ST	
WEST JEFFERSON, NC, 28694	WEST JEFFERSON, NC, 28694	

INSPECTION INFORMATION

Inspection Date 09/11/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ASHE
-------------------------------	----------------------------	---------------------------------	-------------------------	----------------

5

VIOLATIONS

5.1.21.1 Place the car alarm bell in working order. Minimum level of 80 dBA. With power off

Items must be corrected by: 11/10/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Reeves Law Firm 336\_246-7122

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

REEVES LAW FIRM  
PO DRAWER 67  
WEST JEFFERSON, NC, 28694