



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18256-76-529
State Number
4320

EQUIPMENT INSPECTED

State Number: 4320	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 1900	Manuf: SOUTHERN	Speed: 50
Landings: 3	Installed: 02/27/1962	Rope Size:
Volts: 220	Complied: 04/12/2000	Entrances: 1
OWNER	OCCUPANT	
JACK BARR	QUIET COUNTRY AMISH FURN.	
201 MEADOW RIDGE DR.	109 E MAIN ST	
JEFFERSON, NC, 28640	WEST JEFFERSON, NC, 28694	

INSPECTION INFORMATION

Inspection Date 09/13/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ASHE
-------------------------------	----------------------------	---------------------------------	-------------------------	----------------

5

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jack Barr 336-246-2581

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

JACK BARR
201 MEADOW RIDGE DR.
JEFFERSON, NC, 28640