

## N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

## INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm 919-707-7927 Report Number **18256-76-5730** State Number **18561** 

	EQUIF	PMENT INSPECTED		
State Number: 18561	Type of Unit: Passen	ger	Floor to Floor: 1 to 2	
Capacity: 2500	Manuf: KONE		Speed: 100	
Landings: 2 Installed: 06/03/199			Rope Size:	
Volts: 480	Complied: 06/10/199	9	Entrances: 2	
OWNER		OCCUPANT		
		JEFFERSON LANDING		
PO BOX 110		184 WEST LANDING DR. JEFFERSON, NC, 28640		
JEFFERSON, NC, 28640				
	INSPEC	TION INFORMATION		
Inspection Date 09/13/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ASHE
		VIOLATIONS		
2.29.1 Assign identification	on numbers or letters to the equipment where	e required.Elevator room door nee	ds a sign " ELEVATOR ROOM	f"
Items must be corrected by	v: 11/12/2018			
Notify the Elevator Bureau in v complainace with current codes	writing on Corrected Violations Form when ts.	the following corrections have been	en made in order to bring your e	quipment into
Violations pointed out to: Son	ny 336-982-4449		Inspector	
THIS IS NOT AN INVOICE	To make changes to the invoice mailing and invoice will be mailed to:			