



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18261-70-485
State Number
480

EQUIPMENT INSPECTED

State Number: 480	Type of Unit: Freight	Floor to Floor: B to 3
Capacity: 2000	Manuf: OTIS	Speed: 75
Landings: 5	Installed: 01/11/1946	Rope Size: 1/2
Volts: 220	Complied: 01/11/1946	Entrances: 2
OWNER	OCCUPANT	
ACME MCCRARY CORP	ACME MCCRARY CORP	
BOX 1287	159 NORTH ST	
ASHEBORO, NC, 27204-1287	ASHEBORO, NC, 27203	

INSPECTION INFORMATION

Inspection Date 09/18/2018	Type Inspection Routine	Certificate Status Not Issued	Inspector 70 - Darnley	County RANDOLPH
-------------------------------	----------------------------	----------------------------------	---------------------------	--------------------

76

VIOLATIONS

2.2.5.1	Place the freight cab interior lights in working order. 25 lx or 2.5 fc @ the cab floor.
8.6.4.7	Remove the water from the pit floor and take steps to prevent its re-entry.
2.2.5.1	Place the pit lights in working order. 100 lx or 10 fc @ the pit floor.
8.6.4.20.1	Provide the 5 year full load test.
8.6	Put Elevator in proper working condition

Items must be corrected by: 11/17/2018

Elevator Name: RED GATE ELEVATOR

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Grey Plummer 336-625-2161

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ACME MCCRARY CORP
BOX 1287
ASHEBORO, NC, 27204-1287