



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18289-76-4014
State Number
25849

EQUIPMENT INSPECTED

State Number: 25849	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3000	Manuf: OTIS	Speed: 100
Landings: 3	Installed: 06/30/2008	Rope Size:
Volts: 208	Complied: 06/30/2008	Entrances: 1
OWNER	OCCUPANT	
JEFFERSON LANDING	BIRKDALE VILLAS	
P O BOX 110	165 BIRKDALE COURT	
JEFFERSON, NC, 28640	JEFFERSON, NC, 28640	

INSPECTION INFORMATION

Inspection Date 10/16/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ASHE
-------------------------------	----------------------------	---------------------------------	-------------------------	----------------

5

VIOLATIONS

8.6.4.8	Clean the machine room and the machine room equipment.
8.6.5.14.1	Provide the annual relief valve and hydraulic system pressure test.

Items must be corrected by: 12/15/2018

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jefferson Landing 336-982-4449

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

JEFFERSON LANDING
P O BOX 110
JEFFERSON, NC, 28640